

| | | |
|--|--|-------------------------------------|
| NEXANS BOHAIN UNIT F -02110 | <u>CERTIFICAT</u> de conformité RoHS <u>(LSDEE)</u> CERTIFICATE OF CONFORMITY | CCn° 150413 B TECHDH |
|--|--|-------------------------------------|

Object: RESTRICTION of HAZARDOUS SUBSTANCES
Indicated in the DIRECTIVE 2011/65/UE of 8 June 2011
 and indicated in the DIRECTIVES 2006/122/ECOF the European parliament and of the council of 12 December
 2006 amending for the 30th time council Directive 76/769/EEC
 And last EU/ 1 july2008 / exemption.

LISTS of products : **INDUSTRIAL POWER FLEXIBLE RUBBER CABLES**
 Type : **‘TITANEX™ H07RN-F ‘**
 Ranges : **450/750 VOLTS EN 505.25-2-21 (ex CENELEC HD 22-4)**
 and all equivalent national standards
 DIMENSIONS : **All sizes**

Our firm, NEXANS -F 02110 Bohain unit, declares that the following substances
are not introduced during the manufacturing of the cables applying to the Directives
2011/65/UE that:

- Lead (Pb) , - Hexavalent Chromium (Cr 6+) , - Mercury (Hg) , Cadmium (Cd), Polybrominated Biphenyls (PBB)
- Polybrominated Diphenyl Ethers (PBDE) , Penta aromodiphenyl Ether (penta BDE) , Octabromodiphenyl Ether (OctaBDE) , and also : - perfluorooctane sulfonates PFOA and its salts

If any traces of the the aforesaid substances (inferior however to the 0.1% and 0.01% for Cadmium in mass) these must be considered as impurity level, in the raw materials use for the construction of the product, as permitted by RoHS Directives (max level) .

Name and Position of Responsible Manager
Technical DPT Manager
M D. HONG

Control Quality Dpt
M Ph LECLERCQ

Signature:



Signature:



Date 13th april 2015

Unit reference and adress:
NEXANS FRANCE
BOHAIN UNIT 48, rue PAULIN PECQUEUX
02110 -BOHAIN -France
TEL+33 (0)323075150